

M/s. Anchor Electricals Pvt. Ltd. (Unit-V com. building), Survey. No. 32/1, 32/2, & 32/3, Silver Industrial Estate, Village-Bhimpore, Daman was issued Consent to Establish Diesel Generator Sets "D. G. Set 30 KVA" under Air act valid upto 30/09/2016. The activity falls under **Category-III**.

The unit has submitted application for grant of Consent to Operate under Air act on 12/04/2016 along with the following documents;

- Application form no. I under Air Act.
- Declaration giving details of capital investment including land, building and plant & machinery without description.
- Consent fees under Air act for Rs 300 /-.
- Display sign board.
- Application for authorization to handle Hazardous Waste (form-I).
- Industry Data Sheet.
- Copy of Consent to Establish under Air Act.

The unit was inspected on 28/04/2016 at 12:30 hrs. At the time of inspection of the unit following observations were noted:

- Display sign board was properly filled with product and waste generation details.
- The unit was in operation at the time of inspection.
- 30 KVA DG Set was observed installed in the premises of the unit and was provided with acoustic enclose to reduce noise level while operating DG Set.
- A stack was attached with the 30 KVA DG Set having adequate height.
- There were two other DG Sets of 380 KVA capacity each in the premises which have been already issued the consent to operate previously.
- Housekeeping observed during inspection was good.

In view of the above, Consent to Operate Diesel Generator Sets "D. G. Set 30 KVA - No. 1" which falls in **Category-III** under Air act along with terms and conditions as mentioned in annexure-I for the period up to 31/03/2017.

Submitted for your perusal and approval, Sir please

(Signature)
28/04/16

Member Secretary

(Signature)
28/4/16