

0-1104

Name of the unit	Schott Kaisha Pvt. Ltd.	
Address	Sr. No. 50/4, Kadaiya, Bhimpore, Daman.	
Area	Bhimpore	
Category	Category - II	
Applied for	Consent to Operate (D.G. set)	
Consent granted for	Consent to Establish for "D.G. set of 100 KVA"	
Sr. No.	Documents required	Submitted
1.	Application in Form I under Air Act.	Yes (C/905)
2.	Declaration letter showing capital investment.	Yes (C/891)
3.	Consent fees under Water Act and Air Act. (Rs. 1500/-)	Yes (C/917)
4.	Display Sign Board.	Yes (C/897)
5.	Application for authorization to handle hazardous waste and industry data sheet in Form - I.	Yes (C/901)
6.	Industry Data Sheet Format	Yes (C/895)
7.	Copy of Establish consent obtained under water and air act.	Yes (C/879)
8.	Copy of hazardous waste manifest in Form 13.	N.A.
9.	Copy of membership of common TSDF.	N.A.
10.	Copy of analysis of treated effluent.	N.A.
11.	Copy of stack monitoring report and ambient air quality monitoring report.	Yes (C/881)
Effluent discharge with quantity		
	Consumption	Discharge
Domestic water	8.0 KLD	8.0 KLD
Industrial water	--	--
Air Emission		
Installation	Fuel used	Stack/Acoustic
D.G. set (100 KVA)	Diesel	Yes
Details of Effluent Treatment Plant/APCDS		
ETP	N.A.	
APCDS	N.A.	
Monitoring Reports		
Effluent Norms		
	Norms as per consent	As per report
pH	6.5-9.0	--
Suspended Solids	Not to exceed 100 mg/Lit	--
BOD	Not to exceed 100 mg/Lit	--
COD	Not to exceed 250 mg/Lit	--
Oil & grease	Not to exceed 10 mg/Lit	--
Air Emission from stack		
	Norms as per consent	As per report (D.G. set 100 KVA)
Particulate Matter	150 mg/NM ³	48 mg/NM ³

SO ₂	40 mg/NM ³	20 ppm
NOx	25 mg/NM ³	12 ppm
Ambient air emission		
	Norms as per consent	As per report
Particulate Matter ₁₀	100 µg/m ³	--
Particulate Matter _{2.5}	60 µg/m ³	--
NO ₂	80 µg/m ³	--
SO ₂	80 µg/m ³	--

Observations and Recommendations :

The unit was inspected on 07/03/2016 and at the time of inspection following observations were noted:

- Display signboard was prepared and placed at the main gate of premises.
- The unit was in operation at the time of inspection.
- The unit had installed D.G. set of 100 KVA (01 no.) and provided acoustic enclosure.
- The unit has submitted stack-monitoring report for D.G. set of 100 KVA and noise monitoring report.
- The unit was involved in manufacturing of 'Glass ampoules, Glass vials, Prefillable syringes, Dental cartridges - 250000000 MT/Year', for which obtained consent to renewal up to 31/01/2018.

In view of above, if approved Consent to Operate (Category-II) for "D.G. set of 100 KVA (01 no.)" under Air Act for the period upto 28/02/2022 may be issue.

Submitted for your kind perusal and approval, Sir.

[Signature]
15/03/17

Member Secretary

[Signature]

[Signature]
14/3

15/3/17
16/03/17